## TABLE 401.9 ENERGY EFFICIENCY CERTIFICATE

Builder, Permit Holder or Registered Design Pro Print Name: McClay Custom Ho	
Signature: Will m. W	~
	PUT DRIVE
NEW BEKN	N, NC 28562
Date: 10/11/2023	
Insulation Rating – List the value covering largest area to all that apply	R - Value
Ceiling/roof:	R - 38
Wall:	R - 15
Floor:	R - n/a
Closed Crawl Space Wall:	R - 13
Closed Crawl Space Floor:	R - n/a
Slab:	R - n/a
Basement Wall:	R - n/a
Fenestration:	
U-Factor	.29
Solar Heat Gain Coefficient (SHGC)	.28
Building Air Leakage	
■ Visually inspected according to 402.4.2.1 OR	
Building Air Leakage Test Results (Sec. 402.4.2.2) ACH50 [Target: 5.0] or CFM50/SFSA [Target: 0.30]	
Name of Tester/Company: McCLAY CUSTOM HO	OMES ENC, Inc
Date: 06/02/2023 Phone: 252-675-	3323
Ducts:	
Insulation	R -
Total Duct Leakage Test Result (Sect. 403.2.2) (CFM25 Total/100SF) [Target: 6]	Downstairs 4.4 Upstairs 4.5
Name of Tester/Company: C/A HEATING AND AI	R
Date: 09/20/2023 Phone: 252-633-	2744
Certificate to be displayed permanently	